InstruCal Pro

DEMONSTRATION DOCUMENT

Valve test report

Control valve FV-202 | 4-20 mA positioner

Test information

Travel test on a fictional bench

Fictional client: Demo Workshop

Recorded measurements

Command (mA)	Target (%)	Increasing (%)	Decreasing (%)
4.0	0	0.2	0.3
8.0	25	24.8	25.1
12.0	50	49.7	50.1
16.0	75	74.8	75.2
20.0	100	99.9	99.9

Illustrative result

Illustrative maximum error: 0.3 percentage points.

Fictional data, illustrative example.

No actual measurements or declaration of conformity.